

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.6-2007 : Portable fire extinguishers - Specific requirements for carbon dioxide type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	9/09/2019	Certification Expiry Date	10/09/2024
Certificate Issue Date	9/05/2015	Certificate Last Update Date	24/09/2019

APPROVED COMPANY/SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao Zhejiang 315460 China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: F9C4EBD8D0F90D3ACA25847300324C50

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®




Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
CO220A	2.0 Kg CO2 Extinguisher	Presto	2.0 kg Aluminium cylinder, Rating: 5B:E, FERN: 2557.06-104	10/02/2016
CO220A	2.0 Kg CO2 Extinguisher	FireWorld	2.0 kg Aluminium cylinder, Rating: 5B:E, FERN: 2557.06-204	10/02/2016
CO220A	2.0 Kg CO2 Extinguisher	No name	2.0 kg Aluminium cylinder, Rating: 5B:E, FERN: 2557.06-304	10/02/2016
CO220AS	2.0 Kg CO2 Extinguisher	FireWorld	2.0 kg Aluminium cylinder with side horn, Rating: 2B:E, FERN: 2557.06-208	12/03/2017
CO220AS	2.0 Kg CO2 Extinguisher	Presto	2.0 kg Aluminium cylinder with side horn, Rating: 2B:E, FERN: 2557.06-108	12/03/2017
CO220AS	2.0 Kg CO2 Extinguisher	No name	2.0 kg Aluminium cylinder with side horn, Rating: 2B:E, FERN: 2557.06-308	12/03/2017
CO220S	2.0 Kg CO2 Extinguisher	Presto	2.0 kg Steel cylinder with front horn, Rating: 5B:E, FERN: 2557.06-109	12/03/2017
CO220S	2.0 Kg CO2 Extinguisher	No name	2.0 kg Steel cylinder with front horn, Rating: 5B:E, FERN: 2557.06-309	12/03/2017
CO220S	2.0 Kg CO2 Extinguisher	FireWorld	2.0 kg Steel cylinder with front horn, Rating: 5B:E, FERN: 2557.06-209	12/03/2017
CO220SS	2.0 Kg CO2 Extinguisher	No name	2.0 kg Steel cylinder with side horn, Rating: 2B:E, FERN: 2557.06-310	12/03/2017
CO220SS	2.0 Kg CO2 Extinguisher	FireWorld	2.0 kg Steel cylinder with side horn, Rating: 2B:E, FERN: 2557.06-210	12/03/2017
CO220SS	2.0 Kg CO2 Extinguisher	Presto	2.0 kg Steel cylinder with side horn, Rating: 2B:E, FERN: 2557.06-110	12/03/2017
CO235A	3.5 Kg CO2 Extinguisher	No name	3.5 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-305	10/02/2016
CO235A	3.5 Kg CO2 Extinguisher	Presto	3.5 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-105	10/02/2016
CO235A	3.5 Kg CO2 Extinguisher	FireWorld	3.5 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-205	10/02/2016
CO235S	3.5 Kg CO2 Extinguisher	Presto	3.5 kg Steel cylinder, Rating: 5B:E, FERN: 2557.06-107	10/02/2016



Certification Manager





global-mark®

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
CO235S	3.5 Kg CO2 Extinguisher	No name	3.5 kg Steel cylinder, Rating: 5B:E, FERN: 2557.06-307	10/02/2016
CO235S	3.5 Kg CO2 Extinguisher	FireWorld	3.5 kg Steel cylinder, Rating: 5B:E, FERN: 2557.06-207	10/02/2016
CO250A	5.0 Kg CO2 Extinguisher	Presto	5.0 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-106	10/02/2016
CO250A	5.0 Kg CO2 Extinguisher	FireWorld	5.0 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-206	10/02/2016
CO250A	5.0 Kg CO2 Extinguisher	No name	5.0 kg Aluminium cylinder, Rating: 10B:E, FERN: 2557.06-306	10/02/2016
CO250S	5.0 Kg CO2 Extinguisher	Presto	5.0 kg Steel cylinder, Rating: 10B:E, FERN: 2557.06-111	12/03/2017
CO250S	5.0 Kg CO2 Extinguisher	No name	5.0 kg Steel cylinder, Rating: 10B:E, FERN: 2557.06-311	12/03/2017
CO250S	5.0 Kg CO2 Extinguisher	FireWorld	5.0 kg Steel cylinder, Rating: 10B:E, FERN: 2557.06-211	12/03/2017

Comments:

Extinguisher construction complies with AS/NZS1841.1 standard requirements.

End of the document



Certification Manager